



Chhatrapati Sambhajnagar. Municipal Corporation

FIRE BRIGADE

TELEPHONE NO-2334000-40FAX No-2331444

Outward No:CSMC/FIRE/4/6/2026

Date 27 / 02 /2026

To,
Mr. Nandauri Srinivas Nandamuri Bullabbai,
School Building, Gut No. 140/P,
At. Tisgaon, Nagar-1, Sector -D, N.H.4,
Waluj Mahanagar, Chhatrapati Sambhajnagar.

Sub;- Provisional Fire Noc is issued to the School Building, Gut No. 140/P, At. Tisgaon, Nagar-1, Sector -D, N.H.4, Waluj Mahanagar, Chhatrapati Sambhajnagar.

Ref:- 1) Your Letter date 27/02/2026

2) CFO Inspectio on date 27/02/2026

With Reference to the above subject **Provisional Fire Noc is issued to the School Building, Gut No. 140/P, At. Tisgaon, Nagar-1, Sector -D, N.H.4, Waluj Mahanagar, Chhatrapati Sambhajnagar.** Plot area is 8400.00 Sq.mtr.

Owner has paid Fire Fund Rs.562015 /- & Provisional Fire Noc fees Rs. 10,000/- in Fire Brigade in Receipt No. 13547 on date 27 /02 /2026.

S.No	Building	Height	Building	Floor	Area of Plot	Builtup Area	Fire Fund	Noc Fees
1	School Building	08.10 mtr	01	G+2	8400.00 Sq.mtr	4644.78Sq.mtr Per Sq.mtr 121/- 562015.00	562015	10000
							562015	10000


Following Fire prevention and Fire protection & Fire Fighting measures subject to **School Building** shall be provided.

1. Open space around the building shall be provided for the movement of fire tender and which will carry 25 tons. weight capacity.
2. Overhead water tank 10000 Ltr, Booster Pump-900 LPM-01 Nos of suitable Capacity for building Shall be Provided.
3. Fire service inlet 2 way incoming shall be provided.
4. Hydrant points all around the building with fire Hose Pipe/ Branch shall be provided.
5. Wet riser having outlet on all floors with Hose Pipe / Branch shall be Provided.
6. Hose reel of 100 feet on all outlets shall be provided.
7. Fire Extinguisher of / ABC / Co2 of suitable Capacity / quantity shall be provided.
8. Automatic / Munally Sprinkler System, Automatic / Munally Smoke Detector System, Alarm System Manual Call Point, Hooter shall be Provided.
9. 01 Nos. Main Staircase 1.50 Mtr Shall be provided.
10. This Certificate shall be treated valid for a period of one year from, the date of issue up to Final Fire Noc

The Fire Fighting System arregament install ed for proposed area such as hydrant system, Hose reel, fire extinguisher, wet riser, manually operated fire alarm system fire pumps, should be extended to the proposaed construction.

Sr.No.	Fire Fighting Installation	Requirements	Provision	Remarks
	Portable Fire Extinguishers	Required	IS. 15683 & Is. 2190	Portable fire Etinguisher should be installed confirming to IS 15683 & Other I.S Codes
2	Hose Reel	Required Prominent Places	At Varous Strategic Locations	On each floor in the staircase landing for fire fighting thr first and hose reel shall be connected directly to rise r/Down Commer Main and diameter of the hose reel shall not be less than 19 mm Confirming to IS 884. 1985.
3	Court Yard Hydrant or Ring Hydrant System around the building	Required around all Proposed building	Fire Brigade intel connection should be provided hydrant point should be provided with of delivery hose confirming to IS-636 along with standerd Branch. The distance between 2 hydrants should be followed as per IS 3844. 1989 & 13039. 2012	
4	Manually Operated fire alarm System	Requirement	At every floor on strategic location	Manually operated fire Alarm Should be provided. It should be connected to alternate power supply
5	Undergrond Static Storge tank	Requirement		This water storage should be exclusively for fire Fighting
6	Booster Pump	Pump shall be provided		Fire Fighting pmps shall be well maintained A Separate arrangement of pumping should be done for Sprinkler System. All the fire Pumps must be centrifugal pumps only.
7	Fire brigade connection	Required at the Main gate and on fire water tank		For Static water tank and for Hydrant system.

As per BMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006 reference to above subject **Provisional Fire Noc is issued to the Mr. Nandauri Srinivas Nandamuri Bullabbai, School Building, Gut No. 140/P, At. Tisgaon, Nagar-1, Sector -D, N.H.4, Waluj Mahanagar, Chhatrapati Sambhajinagar.**


 Chief Fire Officer
 Fire Brigade, Municipal Corporation
 Chhatrapati Sambhajinagar.

Copy to:- C S T.P, Chhatrapati Sanbhajinagar